

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

TEST REPORT

Client : Paxwood Pty Ltd T/A Clever Choice Design Floors
Unit 1
164 Adderlely Street
West Auburn NSW 2144

Test Number : 21-000760
Issue Date : 10/03/2021
Print Date : 11/03/2021

Sample Description Clients Ref : "Clever Oak 20mm"
Engineered Timber flooring planks
Colour : Oak
End Use : Flooring
Nominal Composition : Solid Oak veneer with multilayer ply core
Nominal Mass per Unit Area/Density : 750kg/m³
Nominal Thickness : 20mm

AS 4586-2013 Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 10/03/2021
Test Temperature (20±5degC) 22 °C
Sample Preparation Washed with pH neutral detergent and dried.
Test Direction Length
Fixed/Unfixed Unfixed
Slider No 96 Batch No 95
Length 1 2 3 4 5 SRV
British Pendulum 28 27 28 27 29 28
Number
Classification P2

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

230753

49854

Page 1 of 1



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Fiona McDonald
APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR